



Annual Drinking Water Quality Report 2015

Town of Pocahontas, VA

300 Centre St.

P.O. Box 128

Pocahontas, Va. 24635

PWS# WV 3302852

PWS# VA 1185625

Date Prepared: 10-22-2016

Why am I receiving this report?

In compliance with the Safe Drinking Water Act Amendments, the **Town of Pocahontas** is providing its customers with this annual water quality report. This report explains where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The information in this report shows the results of our monitoring for the period of January 1st to December 31st, 2015 or earlier if not on a yearly schedule.

If you have any questions concerning this report, you may contact, **Chief Operator 304-248-8156** or **Benjamin Gibson, Mayor at 276-945-9522**. If you have any further questions, comments or suggestions, please attend any of our regularly schedule **Town council meetings** held on the **3rd**. Monday of every month at **7.00 PM** at the **Pocahontas Court House on 117 West Saint Claire Street, Pocahontas, Va.**

Where does my water come from?

Your drinking water source is **surface water** from Big Spring Branch also known as Abbs Creek or Abbs Valley Creek.

Source Water Assessment

A Source Water Assessment was conducted by the West Virginia Bureau for Public Health (WVBPH). The intake that supplies drinking water to the **Town of Pocahontas, VA** has a higher susceptibility to contamination, due to the sensitive nature of surface water supplies and the potential contaminant sources identified within the area. This does not mean that this intake will become contaminated only that conditions are such that the surface water could be impacted by a potential contaminant source. Future contamination may be avoided by implementing protective measures. The source water assessment report which contains more information is available for review or a copy will be provided to you at our office during business hours or from the WVBPH 304-558-2981.

The Virginia Department of Health conducted a source water assessment of our system during 2002. The source was determined to be of high susceptibility using the criteria developed by the state in its approved Source

Water Assessment Program. The assessment report consists of maps showing the source water assessment area, and inventory of known land use activities or concern, and documentation of any known contamination within the last 5 years. The report is available by contacting your water system representative at the phone number or address given elsewhere in this drinking water report.

Why must water be treated?

All drinking water contains various amounts and kinds of contaminants. Federal and state regulations establish limits, controls, and treatment practices to minimize these contaminants and to reduce any subsequent health effects.

Contaminants in Water

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits of contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The source of drinking water (both tap and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals, and, in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring, or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune disorders, some elderly, and infants can be

particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Water Quality Data Table

Definitions of terms and abbreviations used in the table or report:

- **MCLG - Maximum Contaminant Level Goal**, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL - Maximum Contaminant Level**, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technique.
- **MRDLG - Maximum Residual Disinfectant Level Goal**, or the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect benefits of use of disinfectants to control microbial contaminants.
- **MRDL - Maximum Residual Disinfectant Level**, or the highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary to control microbial contaminants.
- **AL - Action Level**, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **TT –Treatment Technique**, or a required process intended to reduce the level of a contaminant in drinking water

Abbreviations that may be found in the table:

- **ppm** - parts per million or milligrams per liter
- **ppb** - parts per billion or micrograms per liter
- **NA** – not applicable
- **NE** - not established
- **NTU** –Nephelometric Turbidity Unit, used to measure cloudiness in water

The **Town of Pocahontas** routinely monitors for contaminants in your drinking water according to federal and state laws. The tables below show the results of our monitoring for contaminants.

Table of Test Results - Regulated Contaminants – 2015 for PWS# WV3302852 and PWS# VA1185625

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
Turbidity	N	.07 100% of monthly samples <0.3	NTU	0	TT met if 95% of samples <0.3	Soil runoff
Total organic carbon	N	1.6	TT	NA	TT met if ≥ 1.0	Naturally present in the environment
Inorganic Contaminants						
Barium	N	.03	ppm	2	2	Discharge from drilling waste; erosion of natural deposits
Aluminum	N	.02	ppm	NA	NA	Naturally present in the environment and in additives used in water treatment process
Copper*	N	.16	ppm	1.3	AL=1.3	Corrosion of household plumbing
Lead*	N	6.5	ppb	0	AL=15	Corrosion of household plumbing
Arsenic	N	ND	ppb	10	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Cyanide	N	ND	ppm	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer plants
Fluoride	N	0.11	ppm	4	4	Erosion of natural deposits
Nitrate + Nitrite	N	1.5	ppm	10	10	Runoff from fertilizer use; leakage from septic tanks, sewage; erosion of natural deposits
Volatile Organic Contaminants						
Chlorine	N	Annual avg. 2.3 Range 0.0 – 2.9	ppm	4 MRDLG	4 MRDL	Water additive used to control microbes

Haloacetic acids (HAAC5)	N	Annual avg. 7.75 Range 5.6-9.9	ppb	NA	60	By-product of drinking water disinfection
Total Trihalomethanes (TTHMs)	N	Annual avg. 6.2 Range 6.1 -6.3	ppb	NA	80	By-product of drinking water chlorination

* Copper and lead samples were collected from area residences on 7/25/2013. Only the 90th percentile is reported. None of the samples collected exceeded the MCL.

** Radioactive Contaminants						
Gross Alpha	N	0.3	pci/L	NA	15pci/L	Erosion of natural deposits of certain minerals that are radioactive
Radium-226	N	0.7	pci/L	NA	5pci/L	Erosion of natural deposits of certain minerals that are radioactive
Radium-228	N	0.8	Pci/L	NA	5pci/L	Erosion of natural deposits of certain minerals that are radioactive

**Radiological constituents are tested every six years. They were last tested on March 24, 2009.

Table of Test Results - Unregulated Contaminants-2015 for PWS# 3302852 AND PWS# VA1185625

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
Sodium*	N	4.4	ppm	NE	20	Erosion of natural deposits
Sulfate	N	10.9	ppm	250	250	Erosion of natural deposits
Chloride	N	9.3	ppm	NE	250	Erosion of natural deposits

*Sodium is an unregulated contaminant. Anyone having a concern over sodium should contact their primary health care provider

Additional Information

All other water test results for the reporting year 2015 were all non-detects.

Turbidity is a measure of the cloudiness in water. We monitor it because it is a good indicator of the effectiveness of our filters.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **Town of Pocahontas** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

This report will not be mailed. A copy will be provided to you upon request at our office during regular business hours.

2015 Violations – West Virginia

- 3/11/15 – Chlorine residual missing on reported bacteriological sample and chlorine Monthly Operating Report not submitted for January 2015
- 3/31/15 - Insufficient chlorine residuals taken during February 2015
- 4/30/15 - Insufficient chlorine residuals taken during March 2015
- 6/11/15 - Insufficient chlorine residuals taken during April 2015
- 7/16/15 – Failure to submit Consumer Confidence Report for 2014 by July 1, 2015
- 7/28/15 - Insufficient chlorine residuals taken during June 2015
- 9/10/15 – Failed to submit or complete Monthly Operating Report for July 2015
- 10/15/15 – Turbidity values and Monthly Operating Report not submitted, and insufficient chlorine residuals taken on bacteriological samples for August 2015
- 12/15/15 – Failure to monitor for Trihalomethanes (TTHMs) at Nemours Post office, and Haloacetic Acids (HAA5s) at Falls Mills Master Meter during 3rd quarter of 2015
- 12/15/15 – Failure to monitor for Disinfectant Byproduct Precursors (TOC and Alkalinity) during 3rd quarter of 2015
- 12/15/15 – Failure to provide public notification of previous violations from August 2014

2015 Violations – Virginia

- 8/5/15 – Failure to adequately record filtered water turbidity, failure to maintain a high degree of reliability to achieve water quality standards, failure to certify development of an Emergency Management Plan for an Extended Power Outage, failure to provide Public Notification of 2014 monitoring violations, failure to provide the Consumer Confidence Report for 2014, failure to implement the Cross Connection Control Plan
- 8/6/15 – Failure to monitor required DBP samples for 1st and 2nd Quarters of 2015, failure to monitor required filtered water TOC samples during 2nd Quarter of 2015, failure to monitor required raw water TOC and alkalinity samples for 2nd Quarter of 2015
- 10/23/15 – Failure to submit Monthly Operating Reports for August 2015 and September 2015, failure to monitor required DBP samples for 3rd Quarter 2015, failure to monitor required filtered water TOC samples for 3rd Quarter 2015, failure to monitor required raw water TOC and alkalinity samples for 3rd Quarter 2015
- 11/13/15 – Failure to monitor filtered water turbidity